The Head Department of Microbiology PAU Ludhiana.

To

The Principal G.N.I Public School, Gujarkhan campus, Model Town, Ludhiana.

Memo. No. 1209 Dated: 10/3/25

Subject:

Bacteriological quality of drinking water (IS-10500:1991.BIS New Delhi). Reference is made to your letter No. nil dated 06.03.2025 regarding water sample for

bacteriological analysis.

REPORT:

	Source	Coliform Organisms		Faecal Coliform /E.coli Detected / Not detected
S. No.	Source	Present/Absent	Most Probable Number index (<10/100ml)	Defected / Not detected
				Not Detected
01	Submersible	Absent		1100 D

INFERENCE

Bacteriologically Safe:- 01

*Bacteriologically not Safe:- Nil

Amandeet Eingh Technician

Water Testing Lab

Department of Microbiology

PAU, Ludhiana

Water Testing Lab

Department of Microbiology

PAU, Ludhiana

Note: This result relates to the sample provided to us and laboratory is not responsible for drawing/collecting of samples. The contents of this report are meant for your guidance and should not be used for Advertisement, Evidence and Litigation. This test document shall not be reproduced without the permission of the University.

Head Colol3 5

*Treatment for non-potable water as per WHO recommendations and 20L of water with 1mL dose of 10% Sodium hypochlorite or 1.8mL dose of 5% Sodium hypochlorite solutions with retention time of 30 Mins. The water must be used within 24 hours of treatment. The solution is available with all the chemical stores.

Gurmant Kaun G.N. International Public School Model Town, Ludhiana-141 092 Affiliation No. 1630130

MUNICIPAL CORPORATION LUDHIANA (HEALTH BRANCH)

TO WHOM IT MAY CONCERN

No. 8196 mon 10 Date: 28/10/2024

Municipal Cor

Ludhiana.

It is intimated that the sanitary condition of the G.N.I Public School, Gujarkhan Campus, Model Town, Ludhiana, Ludhiana is up to mark .School authority ensures the compliance of Solid Waste Management Rules 2016.

> Gusmant Kaus Principal

G.N. International Public School Model Town, Ludhiana-141 0@2 Affiliation No. 1630130